

Floor Number	Location	Inspection Categories										Comments and miscellaneous violations:			
		Electrical	Doors	Detection	Suppression	Storage	Plbg	Surfaces							
	Partly	Exit sign is not illuminated (F-1104.3), or lacks emergency power source (F-1104.4).													Comments and miscellaneous violations: heat coils Christmas light extension to P.S. Clean window coils
		Emergency lights are inoperable or missing (F-1104.5).													
		Light fixtures in the corridor are inoperative (MC 22-702.1 and F-1008.2)													
		Unapproved or damaged wiring, or open splice or box (F-605.1 and F-605.6)													
		Fire doors do not self close and latch, or are blocked open (F-703.2).													
		are missing or not functional (F-110.39 and ILPA 094-0741).													
		Fire alarm components are damaged or missing (F-901.6, F-907.8)													
		Fire extinguisher lacks current service tag, is discharged (F-906.2), or not wall mounted (F-906.7).													
		Fire sprinklers or equipment are obstructed or damaged (F-901.6), F-903.5.													
		The corridor or stairs contain refuse, furniture, or decorations which impede exit (F-1031.2 and F-1031.3).													
		Combustible storage in building interior or mechanical rooms (F-315.3).													
		The plumbing fixtures are inoperative or missing (MC 22-504.1).													
		Hole in wall or ceiling (F-703.1)													
		Broken or cracked windows (MC 22-304.13)													
TOTAL															

Exterior Violations:

Floor Number	Room Number	No violations	Doors	Fire Protection	Candles	Cooking	Electrical	Surface	Miscellaneous / notes:
2	301								
	302								
	303A								
	305		X						
	211								
	209								
	213								
	202								
	205								
	215								
	203		X						
	212		X						
	204		X						
	224		X						
	216		X						
	218								
	202								
	220								
TOTAL									

23

Duct tape on ceiling

resin PS
 partitions in 2nd floor
 elevator light
 need to
 check
 room

ceiling

path of escape
 extension cord/PS
 MCs in Room 305

Miscellaneous / notes: